

Certificate of Conformity

Certificate Number: 190226174GZU-002

On the basis of the tests undertaken, the sample of the below product have been found to comply with the requirements of the referenced specification standard at the time the tests were carried out. This certificate is part of the full test report and should be read in conjunction with it ;

Applicant Name & Address:	EVOLVE ENERGY GROUP CO., LIMITED RM 702,7/F FU FAI COMM CTR 27 HILLIER ST SHEUNG WAN, HK
Product Description:	Solar inverter
Ratings & Principle Characteristics:	See Annex to Certificate of Conformity
Models:	EVVO 3000TL, EVVO 2700TL, EVVO 2200TL, EVVO 1600TL, EVVO 1100TL
Relevant Standards	IEC 61727 2nd ed:2004, Photovoltaic (PV) systems – Characteristics of the Utility interface IEC 62116 2nd ed.:2014, Test procedure of islanding prevention measures for Utility-interconnected photovoltaic inverter
Certificate Issuing Office:	Intertek Testing Services Shenzhen Ltd. Guangzhou Branch
Date of Tests:	27 Feb 2019– 25 May, 2019
Test Report Number(s):	190226174GZU-002 190226174GZU-003

Additional information in Appendix.



Signature

Name: Tommy Zhong
Position: Technical Manager
Date: 04 Jun 2019



This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Certificate are relevant only to the sample tested/inspected. This Certificate by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Certificate of Conformity

This is an Annex to Certificate of Conformity with Certificate/Report Number: 190226174GZU-002; The issuing office is Intertek Legal Entity as above.

Ratings and principal characteristics

Input voltage rang: 100-500 V (for EVVO 3000TL, EVVO 2700TL, EVVO 2200TL);
90-450 V (for EVVO 1600TL, EVVO 1100TL)
MPPT voltage range with full power output: 230-500 V (for EVVO 3000TL);
200-500 V (for EVVO 2700TL); 170-500 V (for EVVO 2200TL); 165-450 V (for EVVO 1600TL);
110-450 V (for EVVO 1100TL)
Max. input current: 13 A (for EVVO 3000TL, EVVO 2700TL, EVVO 2200TL);
10 A (for EVVO 1600TL, EVVO 1100TL)
Nominal output voltage: 230 V
Max. output current: 13 A (for EVVO 3000TL); 11.5 A (for EVVO 2700TL);
9.5 A (for EVVO 2200TL); 7 A (for EVVO 1600TL); 4.5 A (for EVVO 1100TL)
Nominal frequency: 50 Hz
Max. output power: 2800 W (for EVVO 3000TL); 2500 W (for EVVO 2700TL);
2000 W (for EVVO 2200TL); 1500 W (for EVVO 1600TL); 1000 W (for EVVO 1100TL)
Ingress protection: IP65
Operating temperature range: -25~60°C

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Certificate are relevant only to the sample tested/inspected. This Certificate by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.